

EVALUATION OF LIGHTNING HAZARDS TO MUNITION STORAGE HANDLING, AND MAINTENANCE FACILITIES WITH THE USE OF ADVANCED METHODS FOR SOLUTIONS OF MAXWELL'S EQUATIONS *

By

**Richard S. Collier
Rodney A. Perala**

**Electro Magnetic Applications, Inc.
12567 W. Cedar Drive, Suite 250
Lakewood, Colorado 80228-2091
(303) 980-0070**

ABSTRACT

Munition storage, handling, and maintenance facilities consist of a variety of structures. They include buried rebar re-enforced concrete walled igloos of several types, as well as above ground buildings. One of the safety hazards of concern is the protection of these munitions from the effects of lightning. These structures are electromagnetically complex, because they consist of a variety of inhomogeneous materials (e.g., concrete with rebar) which may be either conducting or partially conducting. In addition, the structures usually have metallic penetrations such as electrical cables or plumbing, as well as a lightning protection system including an earth ground of some type.

The objective of this paper is to describe how the lightning hazards to such structures can be evaluated using advanced formulations of Maxwell's Equations. The method described is the Three Dimensional Finite Difference Time Domain Solution. It can be used to solve for the lightning interaction with such structures in three dimensions and include a considerable amount of detail.

Examples of lightning strikes to buried igloos and above ground buildings will be presented. The physical details which are included in the models are discussed. The results include the voltages and currents induced on conductors which penetrate the facility, as well as the internal electric and magnetic fields. Possibilities for internal arcing are described. These results can then be used to evaluate the possible hazard to materials stored inside. Of special interest is the evaluation of the effectiveness of earth ground systems and how they affect energy penetration to the facility interior.

1.0 INTRODUCTION

Lightning hazards to explosives storage, handling, and maintenance facilities can be described in terms of electric and magnetic fields (and their time derivatives) and the resulting direct

* Work sponsored by Picatinny Arsenal Under Contract # DAAA21-89-C-0176

Report Documentation Page				Form Approved OMB No. 0704-0188	
Public reporting burden for the collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington VA 22202-4302. Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to a penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number.					
1. REPORT DATE AUG 1990		2. REPORT TYPE		3. DATES COVERED 00-00-1990 to 00-00-1990	
4. TITLE AND SUBTITLE Evaluation of Lightning Hazards to Munition Storage Handling and Maintenance Facilities with the Use of Advanced Methods for Solution of Maxwell's Equations				5a. CONTRACT NUMBER	
				5b. GRANT NUMBER	
				5c. PROGRAM ELEMENT NUMBER	
6. AUTHOR(S)				5d. PROJECT NUMBER	
				5e. TASK NUMBER	
				5f. WORK UNIT NUMBER	
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) Electro Magnetic Applications, Inc, 12567 W. Cedar Drive, Suite 250, Lakewood, CO, 80228-2091				8. PERFORMING ORGANIZATION REPORT NUMBER	
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES)				10. SPONSOR/MONITOR'S ACRONYM(S)	
				11. SPONSOR/MONITOR'S REPORT NUMBER(S)	
12. DISTRIBUTION/AVAILABILITY STATEMENT Approved for public release; distribution unlimited					
13. SUPPLEMENTARY NOTES See also ADA235005, Volume 1. Minutes of the Explosives Safety Seminar (24th) Held in St. Louis, MO on 28-30 August 1990.					
14. ABSTRACT see report					
15. SUBJECT TERMS					
16. SECURITY CLASSIFICATION OF:			17. LIMITATION OF ABSTRACT Same as Report (SAR)	18. NUMBER OF PAGES 14	19a. NAME OF RESPONSIBLE PERSON
a. REPORT unclassified	b. ABSTRACT unclassified	c. THIS PAGE unclassified			

and induced electrical currents which are found in and around critical locations of the facility during a lightning strike.

The space and time distributions of such fields and currents follow solutions of Maxwells Equations providing that appropriate initial and boundary conditions can be supplied in the regions of interest and that a method of solution can be applied.


This paper describes a numerical computer model which applies Maxwells Equations to describe a specified lightning attachment to a specific building or facility. The result shows how electromagnetic fields and currents are distributed in space and time in and near the facility during the lightning strike.

Examples are given; 1. For an earth covered storage igloo with iron rebar re-enforced concrete walls, and 2. For a rectangular building with cinder-block walls and a metal roof. Both structures have provisions for "lightning protection" in the form of air terminals connected to a ground counterpoise system. It will be shown that fields and currents within these structures can be significantly high during a lightning strike.

2.0 DESCRIPTION OF THE NUMERICAL MODELS

The numerical model of the structure and surrounding environment is based upon a finite difference time domain solution of Maxwell's equations. The solution technique is explicit and accurate to second order in the time and spatial increments, which in these models correspond to the three dimensional cartesian coordinate increments as obtained by Merewether and Fisher [1].

A problem space containing the facility and surrounding environment is divided into rectangular cells. Each cell has a staggered spatial grid, as shown in Figure 1, composed of the vector components of E and H. There are approximately one million cells in the lightning strike problem spaces discussed in this paper. The cell dimensions Δx , Δy and Δz are 12"x6"x6" for the igloo and 6"x12"x12" for the building. The field components in each cell are calculated numerically via the finite difference form of Maxwell's Equations [1].



MAXWELL'S EQUATIONS

$$\mu \frac{\partial H}{\partial t} + \nabla \times E = M \quad (1)$$

$$\epsilon \frac{\partial E}{\partial t} + \sigma E - \nabla \times H = -J \quad (2)$$

$$\nabla \cdot E = \frac{\rho}{\epsilon} \quad (3)$$

$$\nabla \cdot H = 0 \quad (4)$$

Figure 1 Staggered Spatial Grid

The time step (increment) for this finite difference solution of Maxwell's equations is determined by the Courant criterion, which may be viewed as requiring that the speed of numerical propagation be greater than the fastest physical wave speed, in this case the speed of light in air. Specifically, the Courant condition is:

$$\Delta t \leq \frac{1}{c \sqrt{\frac{1}{\Delta x^2} + \frac{1}{\Delta y^2} + \frac{1}{\Delta z^2}}} \quad (5)$$

where Δt is the time step, Δx , Δy , and Δz are the three cartesian spatial increments and c is the speed of light in the air. For the igloo Δt is $.25 \times 10^{-9}$ s and for the building Δt is $.33 \times 10^{-9}$ s. The smallest spatial increments control the time step, but the largest spatial increments determine the bandwidth of the solution. The rule of thumb used is that the upper frequency limit of the solution, f_{\max} , is given by

$$f_{\max} = \frac{c}{5 \max(\Delta x, \Delta y, \Delta z)} \quad (6)$$

For the igloo and building models discussed here, this corresponds to an f_{\max} of a few hundred MHz, which is more than sufficient for the worst case lightning environment scenario.

Maxwell's curl equations (1), (2) form a system of hyperbolic partial differential equations which not only require initial conditions at all spatial locations, but also the boundary values of the electromagnetic field components (or their normal derivatives) at all times to obtain a well posed solution. These values must be supplied at the boundaries of the computational volume by an appropriate termination condition. The boundary condition employed was derived by Mur [2], and is essentially a first order integration along outgoing (with respect to the interior of the computational volume) characteristics. That is, the characteristic direction is chosen to be causal in time and along the outward normal to the bounding surface, which is a two dimensional cartesian coordinate plane. Boundary conditions also must be imposed on metallic surfaces such as the door, interior wall and metal equipment. The boundary condition on metal surfaces at least as large as a cell face is that the tangential electric fields at the surfaces of the metallic objects are set equal to zero each time step. Although this is correct only for perfect electrical conductors, on the time scale of interest, it is an excellent approximation.

If the Maxwell divergence equations (3, 4) are satisfied at the initial time step then the finite difference time development of the curl equations automatically satisfy the divergence equations at each time step. Thus the static solution in the problem space satisfying (3) and (4) is tantamount to specifying the initial conditions for the problem. The simplest initial condition is to set $E = H = \rho = 0$ throughout the problem space. However, physically, a lightning discharge is normally a dynamic release of a static field buildup between the cloud and ground. The building or facility under consideration will usually cause local static field enhancements from the charge buildup between cloud and ground. The air dielectric breakdown will then usually occur at the point of highest electric field, e.g., an air terminal or protrusion of the structure.

Thus it is sometimes necessary to obtain the initial static solution for the facility under high field conditions in order to faithfully track the fields and currents of the resulting lightning strike.

At other times it may be sufficient to realize that under linear conditions and a given lightning current injection waveform, the final solution is the superposition of the initial static solution and a dynamic solution with the initial fields and charge density set to zero. This paper will be primarily concerned with the dynamic part of the solution under zero initial conditions.

In addition to the appropriate boundary and initial conditions, the material properties at each cell location must be specified. This consists of the magnetic permeability, μ , in equation (1); the conductivity, σ , in equation (2) and the dielectric constant, ϵ , in equations (2) and (3). If the material is homogeneous within the cell (for example, volumes of air, soil, concrete, etc.) then the appropriate values of μ , σ , and ϵ are included in the time advance equations for the cell in question.

If the material properties are inhomogeneous in each cell (detailed structure, etc.) then a decision must be made on how to represent the properties in each cell. In some cases average properties are sufficient and in other cases they are not. Special considerations are available for treating apertures in metal walls and also for pipes and thin wires (radii much smaller than cell dimensions) which may run throughout the problem space. These pipes and wires can be carriers of high current.

The buildings and facilities of interest usually have a great deal of "thin wire" situations in the form of signal and power lines, rebar in reinforced concrete, pipes, plumbing, metal poles, the lightning protection air terminals, down conductors, counterpoise, etc.

The thin wires and rods are implemented in a self consistent fashion by making use of the telegrapher's transmission line equations. The telegrapher's equations (7), (8) are a one dimensional solution of Maxwell's in terms of currents, I_w , and voltages, V_w , on the wires, which are required to have diameters less than cell size (spatial increment). The per unit length inductances and capacitances are defined (9), (10) with respect to the cell size and the wire diameter, $2a$.

One Dimensional Transmission Line Equations:

$$\frac{\partial V_w}{\partial z} = -L_w \frac{\partial I_w(k)}{\partial t} - I_w R_w + E_z(i_w, j_w, k) \quad (7)$$

$$\frac{\partial I_w}{\partial z} = -C_w \frac{\partial V_w}{\partial t} - G_w V_w \quad (8)$$

where L_w and C_w is the in-cell inductance and capacitance of the wire per unit length.

$$L_w = \frac{\mu_0}{2\pi} \ell \ln \left(\frac{\Delta y}{2a} \right) \quad (9)$$

$$C_w = \frac{2\pi a \epsilon E_r(a)}{V_w} = \frac{2\pi \epsilon}{\ell \ln \left(\frac{\Delta y}{2a} \right)} \quad (10)$$

G_w is the in-cell conductance from the wire to the surrounding conductive medium

$$G_w \equiv \frac{\sigma}{c} C_w \quad (11)$$

The wire resistance per unit length, R_w , is obtained by considering the surface conduction of the metal in question using the skin depth obtained for a frequency of 1 MHz. The resistance for pipes, wire, iron rebar, etc., is normally on the order of 10^{-3} Ohms/meter. In practice, the major results at early time seem to be relatively insensitive to variations of the resistance.

In the computer code, the wires and pipes are embedded into the staggered grid and are driven by the electric field component (see equation (7)) calculated by the three dimensional solution of Maxwell's equations. In order to maintain electrical charge conservation, this wire current must also be injected back into the driving electric field component as a source current via Maxwell's Equation (2). At the interconnections, which are voltage nodes, Kirchhoff's law is invoked. At locations where the wires are situated in the soil or concrete, the wires are in electrical contact with the soil or concrete with in-cell conductance given by G_w in equation (11). This is also true of the facility ground wire which is in contact with the soil.

Complex networks of thin wires (e.g., concertina or metal rebar mesh embedded in conducting concrete) are included in the model by a vectorized extension of the transmission line formalism. Vectorized average wire currents coincide with the electric field vectors in each cell and a corresponding average inductance and resistance is associated with each wire current vector. Six component tensors exist at the cell corners (nodes) describing the equivalent transmission line voltages, wire capacitance, and conductance to the embedding medium. A 36 component connectivity tensor exists at each node describing the ways that wires are connected at the nodes.

At the boundaries of the problem space, some termination condition must be applied to both the counterpoise extensions and the power and signal lines and metal pipes entering the problem space. The boundary condition is applied at current nodes and is the equivalent of the Mur boundary condition applied to the magnetic fields [2].

3.0 THE LIGHTNING STROKE CURRENT WAVEFORM AND INJECTION

The problem is initiated by imposing a pre-determined lightning wave form from the top edge of the problem space to a specific point on the structure. In a typical computational case described below, the lightning current waveform is characteristic of a 1% stroke of negative lightning. The lightning current, $I(t)$, is given as a function of time by

$$I(t) = 1.1 \times 10^5 \sin^2 \left(\frac{\pi t}{10^{-6}} \right) \text{ A} \quad (12)$$

$$0 \leq t \leq .5 \times 10^{-6} \text{ s}$$

$$I(t) = 1.1 \times 10^5 \sin^2 \left(\frac{t - .5 \times 10^{-6}}{5 \times 10^{-5}} \right) \text{ A}$$

$$.5 \times 10^{-6} < t$$

which has a peak current of 110 kA occurring at .5 μ s. The lightning current appears without propagation delays in a line of vertical electric fields (E_z) from the top of the computational volume to the attach point. The lightning current is injected into the electric fields by dividing the current by the cell area whose normal is parallel to the vertical direction. This becomes the source current density, J , in Maxwell's equation (2). A number of different parameters are studied: lightning stroke attachment location, soil electrical conductivity, structure wall rebar composition, and power box attachment at the walls and ceiling. These parameters are varied in order to provide environments based upon the range of situations which could be encountered.

The computer model contains features of interest such as, soil, concrete, rebar, counterpoise, etc., which are included in the computer model in a modular form. These separate features may be included or excluded from the model by calling subroutines specific to the features desired. The computations are performed on a CRAY II computer. Typical run times are 1 hour of computer time for each microsecond of real time.

4.0 LIGHTNING STRIKE MODELS

The analysis of the preceding sections has been applied to two structures: (1) an earth covered storage igloo with iron rebar reinforced concrete walls as shown in Figure 2 and, (2) a rectangular constructed building with a metal roof as shown in Figure 3.

The igloo interior is completely surrounded with either metal or iron rebar which forms a "leaky" electromagnetic shield for the interior. A schematic drawing of the igloo vertical mid-cross-section is shown in Figure 4.

The building is made of concrete block outer walls with no rebar, a metal roof, and concrete with rebar floor and inner walls with rebar. Thus the building cannot be considered as having a contiguous shielding effect.

For both models the numerical computer output from a simulated lightning strike may be categorized as follows:

1. Contour Plots - These are "snapshots in time" of the electric and magnetic field structures on a plane cross-section of the building at some time after the initiation of the strike.
2. Time Dependent Plots - these are time dependent graphs of electric and magnetic fields at selected points in the problem space. Currents and voltages on thin wires and rods also have time dependent plots at selected points.
3. Current Arrays - These are spreadsheet tabulations of wire currents in specific areas of the building.
4. Field Maxima - These are computer searches at selected times to find the maximum electric and magnetic fields and the maximum time derivative of the magnetic field within a specified boundary inside the building.

Figure 5 shows a contour plot of the vertical mid-plane longitudinal cross-section of the igloo corresponding to the schematic in Figure 4. The electric field pattern outlines some of the prominent features of the igloo, i.e., the z-age, soil berm over the igloo, headwall, backwall, etc.




Figure 2 Earth Covered Storage Igloo -- Lightning Strike Model




Figure 3 Building - Right Side View With Window Screens and Lightning Protection System




Figure 4 Igloo Vertical Cross-Section at $j = j_m = 75$




Figure 5 Electric Field Vector and Magnitude Contour Plot for Vertical Mid-Cross-Section of Igloo

The vectors show the projection of the electric field vector at each cell onto the mid-plane at a time 1 μ sec after the initiation of the strike. The length of the vector is proportional to the logarithm of the electric field. The contour lines show lines of equal electric field magnitude labeled as powers of 10 of the field magnitude in volts per meter. For example, the line labeled 4.0 represents field magnitudes of 10,000 volts/meter.

Figure 6 shows a contour plot on a vertical x-z plane of the building cutting through wire mesh on the window nearest the strike. The view is as if looking from the back of the building. The field patterns show essential geometrical features of the model, i.e., roof, supporting I-beams, outer wall, etc.

The window mesh, a wire grid covering the building windows, is being charged (note E-field vectors pointing away from the mesh) and appears to focus the electric field into the interior of the building. The field levels are very high within the building approaching 1 Megavolt/meter (contours are labeled as powers of 10 of the electric field magnitude).

In this case, Figure 6, the lightning protection system is not connected to the metal roof. At .462 μ seconds the top of the roof is positively charged and the bottom of the roof is negatively charged.

Figure 7 shows the effect of adding an I-beam (perpendicular to the contour plane) with a hanging metal cable hoist. The field at the bottom of the hoist is on the order of a few megavolts/meter and represents a potential for arcing between the hoist and the floor rebar (or any other piece of grounded equipment). In this case the lightning protection system is in contact with the metal roof which is also in contact with the I-beam.

Figure 8 shows time dependent plots, corresponding to Figure 7, of the lightning injection current (given by equations (12)), the electric field and wire voltage in the middle of the window screen, and the voltage between the hoist hook and the floor rebar. This is a case showing that connecting the lightning protection system to the building structure can enhance the hazard inside the building.

5.0 INDUCTIVE AND CAPACITIVE COUPLING TO THE INTERIOR OF THE IGLOO

The construction of the igloo provides that the interior of the igloo is completely surrounded by a "leaky" electromagnetic shield consisting of rebar in conductive concrete and metal doors, walls, etc. It is of interest to examine the character of electromagnetic energy leaking into the igloo interior from the point of view of the model.

Figure 9 shows time dependent plots the lightning injection current waveform at the air terminal and electric field components at a point on the igloo center line near the back wall and ceiling of the igloo. In this case the igloo contains only the internal metal wall. The strong E_x component of the field peaks at .5 μ sec and its waveform appears to follow the time derivative of the lightning current injection waveform. This is interpreted to mean that there is an inductive coupling between currents flowing on longitudinal elements of rebar and the interior electromagnetic field.




Figure 6 Electric Field Vector and Magnitude Contour Plot for a Vertical Plane Passing Through the Window Mesh of the Building







Figure 7 Electric Field Vector and Magnitude Plot for Building Showing the Effect of an Internal I-Beam and Metal Cable Hoist




INJECTION CURRENT - M&A i_r, j_m, k_r-2
FLOOR REBAR - INNER WALL & I-BEAM - CON
.01 SOIL-.001 CONCRETE-DATASETS MAMOS



EX-FIELD
 $i_r+1, j_{ff}+23, k_r+14$
MIDDLE OF WINDOW SCREEN




WIRE VOLTAGE
 $i_r, j_{ff}+23, k_r+14$
MIDDLE OF WINDOW SCREEN




HOIST HOOK
 $i_r+17, j_{ff}+23, k_r+21$ to 23
HOIST HOOK TO FLOOR REBAR


Figure 8 Time Dependent Plots of Building Fields and Lightning Injection Current




CURRENT - BACK AIR TERMINAL
METAL WALL ONLY - 1ftx3ft. REBAR IN ARCH
.01 SOIL-.001 CONCRETE-DATASETS DVJ09



EX-FIELD
1b-2, jn, kt+15
BACK, MIDDLE, UPPER



EY-FIELD
1b-2, jn, kt+15
BACK, MIDDLE, UPPER



EZ-FIELD
1b-2, jn, kt+15
BACK, MIDDLE, UPPER

Figure 9 Time Dependent Plots of Electric Field Components for a Point in the Igloo and the Lightning Injection Current on the Back Air Terminal

In contrast, the vertical E_z field peaks at 1 μsec and its waveform is similar to the lightning current injection waveform except that it decays more rapidly. This is presumably capacitive coupling due to charge collecting on the rebar which is in contact with the lightning protection system at several different grounding locations. The decay in field strength at late time appears to be due to charge leaking off the rebar onto the counterpoise system and by conduction through the concrete and soil.

The inductive and capacitive coupling is illustrated globally by comparing interior field contour plots at .5 μsec (Figure 10) and 1 μsec (Figure 11). In Figure 10 the E_x component is large throughout much of the interior and at later time (Figure 11) the vertical E_z field dominates.

The charge collecting on the rebar may be noted in Figures 10 and 11 by observing electric field vectors pointing away from the ceiling and back wall in both directions.

It is noted that the largest fields are near the floor in both figures and are on the order of 100 Kvolts/meter at 1 μsec . This is due primarily to capacitive coupling of charge on the rebar which, again, is enhanced by electrical contact between the lightning protection system and the igloo metal structure.

6.0 CONCLUSIONS

A numerical computer model of Maxwell's Equations has been applied to buildings typical of munitions storage and handling structures to calculate potential hazards due to lightning strikes. It is seen that detailed electromagnetic field profiles and currents may be calculated which estimate in a realistic manner the hazardous areas in and around the facility. The possibility of both inductive and capacitive electromagnetic coupling to the interior of the structures has been demonstrated. This coupling can be enhanced by electrical contact between the lightning protection system and the metal structural components of the facility. Hazardous non-linear effects such as electrical arcing and explosive decomposition of building structure (e.g., shrapnel from pieces of exposed wood or concrete) are possible for the calculated examples. These results and techniques may be applied to evaluate potentially hazardous explosive storage and handling situations.

7.0 REFERENCES

1. Merewether, D.E., and R. Fisher, "Finite Difference Solution of Maxwell's Equations for EMP Applications," Electro Magnetic Applications, Inc. Report, EMA-79-R-4, Final Revision, 1/15/82.
2. Mur, G., "Absorbing Boundary Conditions for the Finite Difference Approximation of the Time-Domain Electromagnetic-Field Equations," IEEE Trans. EMC, EMC-23, 4, pp. 377-382, November 1981.
3. Saroja, E., "Betonin Ominavastus," Voima Valo 32, pp. 84-86, 1963.




Figure 10 Electric Field Contour in Igloo After .5 μ sec




Figure 11 Electric Field Contour in Igloo After 1 μ sec